

Sun Petrochemicals Private Limited

8th, 9th & 10th Floor, ATL Corporate Park, Saki Vihar Road,
Powai, Mumbai - 400 072, Maharashtra, BHARAT.

CIN: U24219GJ1995PTC028519

Tel: +91 22 69325300

Website: www.sunpetro.com; Email Id: info.sunpetro@sunpetro.com



No. SunPetro/Bhaskar/WMS/2025-26/SPPL-226/Bulletin-3

Date: 30.09.2025

BULLETIN #3

Sub: Real-Time Monitoring and Control System for Bhaskar-I Field in Gujarat

Ref: Tender No. SunPetro/Bhaskar/WMS/2025-26/SPPL-226

Sun Petrochemicals Private Limited (SunPetro), hereby authorizes following amendment / clarification in the above referred Tender:

S. No.	Bidder Query	SunPetro Response
1	Can any reputed make of PLC be supplied against Emerson RTU?	No, only Emerson RTU to be supplied.
2	What is the existing RTU (Make, Model, Architecture)?	Emerson Control Wave
3	Can Siemens Based PLC system be provided instead of Control Wave RTU?	Considering existing setup, we are not considering PLC based architecture.
4	Can the bidder supply their own make RTUs as Control Wave Micro RTUs are Emerson Product?	The specifications of the RTUs will be as per scope. Kindly follow the same and quote accordingly.
5	Kindly share the well parameters which you need to integrate with the SCADA And PLC.	Minimum of 8 to maximum of 12 parameters eg. PT, TT, Pump, VFD etc.
6	Need the Existing / Format of Report File which should be evaluated for the reporting software.	Report format will be finalised as per requirement

All other terms and conditions of the Tender remain unchanged.

Regards,

Sun Petrochemicals Pvt. Ltd.