Sun Petrochemicals Private Limited

Corporate Office: 8th, 9th & 10th Floor, ATL Corporate Park, Saki Vihar Road,
Powai, Mumbai - 400 072, Maharashtra, BHARAT.
CIN: U24219MH1995PTC464242
Tel: +91 22 69325300, + 91 22 28470484
Website: www.sunpetro.com

Tender No. SunPetro/Gujarat/Porta Cabins/2026-27/SPPL-304/Bulletin-1 **Date: 21.10.2026**

BULLETIN #1

Sub: Rate Contract for Supply & Installation of New Porta Cabins, Repair / Maintenance / Renovation of existing Porta Cabins and other associated works with Porta Cabins for SunPetro' s Oil & Gas fields in Gujarat

Ref: SunPetro/Gujarat/Porta Cabins/2026-27/SPPL-304

Sun Petrochemicals Private Limited (**SunPetro)**, hereby authorizes the following amendment / clarification in the above referred Tender:

Sr. No.	Bidder Query	SunPetro Response
1	Are Base Periphery Section and Intermediate Horizontal section Hollow Rectangular section?	Periphery section should be hollow section 80X80X4.5 & interconnection section should be 80X40X3.
2	Serial No. 5.1 Details of structure states Base plate - MS 3 mm and Serial No. 5.6 Flooring System states bunk bottom should have MS sheet of 5 mm thickness. Please clarify both requirements.	Base plate should be 5mm/MS
3	Serial No. 5.1 Details of structure states Ceiling plate - GI 2 mm and Serial No. 5.5 Inner paneling states paneling of roof will be of 8 mm thick prelaminated decorative boards. Please clarify these requirements.	Structural ceiling plate should be 1.5mm Mild steel, if top roof canopy applicable. Without top roof canopy it should be 3MM mild steel plate.
4	Serial No. 5.1 Details of structure states Roof 2 mm GI plain sheet and Serial No. 5.7 Roof states self-draining type roof will be made out of 16-gauge (1.6 mm) thick MS sheet. Please clarify.	Self-draining 16-gauge MS Sheet may be considered.
5	Serial No. 5.1 Details of structure states Exterior GI corrugated sheet - 1.6 mm and Serial No. 5.3 Side & End Walls states Exterior wall made up of 18 SWG (1.22 mm).	Exterior wall sheet should be 2mm corrugated mild steel sheet for welding feasibility.
6	Serial No. 5.1 Details of structure states Main door of ACP sheet and Serial no. 5.7 Main Entry Door states the door interior will be finished with the same material matching that of the bunk house interior.	Door interior to match bunk interior finish

All other terms and conditions of the Tender remain unchanged.

Regards,

Sun Petrochemicals Pvt. Ltd.